

DCS2 - Discharge Point

Parameter	Discharge Consent Threshold	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2014	14/01/2015	04/02/2015	Duplicate/DCS7	11/02/2015	Duplicate/DCS7	Duplicate	23/03/2015
Total Suspended Solids	50	10	3	11	18	22	6	<3	13	11	8	3
Biochemical Oxygen Demand	10	1	<1	<1	<1	1.58 <sup>#</sup>	1.76 <sup>#</sup>	1.61 <sup>#</sup>	1.03 <sup>#</sup>	<1	<2	<2
pH	>6 & <9	-	7.38	7.47	7.08	7.18	7.34 (7.00)	6.92	7.5 (7.48)	7.68	7.8	7.7
Total zinc <sup>4</sup>	33.8	3	<18	<18	30	30	<18	<18	<18	<18	11.47	10.21
Dissolved mercury <sup>4</sup>	1.7	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.2	<0.2
Dissolved cadmium <sup>4</sup>	0.7	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.09	<0.09
Dissolved iron <sup>4</sup>	3.9	0.0047	<0.23	<0.23	<0.23	<0.23	<0.23	0.34	<0.23	<0.23	0.04908	0.03045
Dissolved copper <sup>4</sup>	16.2	3	12	10	<9	<9	<9	<9	<9	<9	9.065	7.101
Dissolved chromium <sup>2</sup>	8.1	0.2	<2	<2	2	7	2	<2	<2	<2	<0.68	<0.68
Chromium VI	N/A	2	<5	<5	<5	9	<5	<5	<5	<5		
Chromium III	N/A	2	<30	<30	<30	<30	<30	<30	<30	<30		
Dissolved nickel <sup>3</sup>	20	0.2	<3	<3	6	14	10	<3	14	11	12.01	6.544
Dissolved arsenic <sup>1</sup>	50	0.9	1	<1	<1	3	4.8	1.1	5.1	4.3	6.23	2.971
Dissolved lead <sup>3</sup>	7.2	0.4	<6	<6	<6	<6	<6	<6	<6	<6	<0.173	<0.173
Total hardness as CaCO3	N/A	1	123	137	132	135	137	24.1	150	146	139	136
Visible oil or grease	N/A	N/A	-	-	-	-	-	-	-	-	-	-

Notes:

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are in µg/L.

<sup>1,2&3</sup> Discharge Consent Threshold from The Water Framework Directive (Priority Substances and Classification) Regulations (Northern Ireland) 2011

<sup>1</sup> Annual mean value presented for 'Good Standard for rivers and freshwater lakes'

<sup>2</sup> Annual mean environmental standard for chromium III (4.7µg/L) plus annual mean environmental standard for chromium VI (3.4µg/L) presented for 'Good Standard for rivers and freshwater lakes'

<sup>3</sup> Annual mean environmental standard (AA-EQS) value presented for priority substance and its compounds for all rivers and lakes




<sup>4</sup> Department Specific

<sup>#</sup> BOD over diluted, therefore result indicative only

<sup>Δ</sup> Container with headspace

Exceedance of threshold

Duplicate sample



Notes:

Half detection limit used for graphing when parameter less than detect

Error bars of 20% to reflect limit of acceptable duplicate reproducibility

26/03/2015	Duplicate	23/04/2015	Duplicate	28/05/2015	28/05/2015	02/06/2015	30/07/2015	04/08/2015	Duplicate	02/09/2015	28/09/2015	Duplicate	01/10/2015	22/10/2015	Duplicate	05/11/2015	Duplicate
27	31	7	10	23	36	39	<10	14	23	11	<10	12	12	<10	<10	<10	<10
1.23 <sup>#</sup>	<2	1.04 <sup>#</sup>	<2	1.71 <sup>#</sup>	1.49 <sup>#</sup>	<1	<1	1	8	3	3	3	2	2	1	1	<1
7.83 (8.54)	7.8	7.83	7.9	8.29	8.27	7.82	7.98	7.69 (8.41)	7.7	8.09	7.74	7.73	8.96	7.35	7.14	7.85 (7.53)	8.06
<18	30.07	<18	<3.73	17.8	14.6	<18	4	6	14.59	13	28	31	7	12	10	5	5
<0.1	<0.2	<0.1	<0.04	<0.01	<0.01	<0.1	<0.01	<0.01	1.051	<0.01	<0.5	<0.5	0.5	<0.5	<0.5	<0.5	<0.5
<0.6	<0.09	<0.6	<0.05	<0.1	<0.1	<0.6	0.13	0.06	0.121	0.36	0.2	0.21	0.25	0.16	0.21	0.24	0.14
<0.23	0.8087	<0.23	0.18	<0.019	<0.019	<0.23	<0.0047	0.1384	0.9932	0.0082	0.5821	0.5538	0.3261	0.6625	0.6613	0.2782	0.2208
10	2.202	<9	4.765	9.39	8.77	<9	<3	<3	13.99	<0.3	5	5	4	<3	<3	<3	<3
<2	<0.68	<2	<0.28	2.13	2.01	<2	<0.2	<0.2	<0.68	0.6	<0.2	<0.2	0.2	<0.2	<0.2	<0.2	<0.2
<5		<5		<30	<30	<5	<2	<2		<2	<2	<2	<2	<2	<2	<2	<2
<30		<30		<30	<30	<30	<2	<2		<2	<2	<2	<2	<2	<2	<2	<2
5	0.833	7	5.578	5.22	5.09	5	6.5	7	9.321	5.3	5	4.9	2.7	3.3	3.7	5.5	5.2
7.9	1.929	2.5	2.214	16	13.7	7.7	6.7	6.5	8.64	4.2	7.5	6.5	4.7	3.5	1.8	3.2	3.9
<6	<0.173	<6	<0.12	<0.02	<0.02	<6	2.6	2.5	0.37	4.7	4.4	4.5	<0.4	1.9	1.8	3.6	2.8
106	114	147	159	140	148	141	179	175	183	163	157	157	93	167	168	197	198
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

## DCS1 - Curraghinalt Burn upstream

Parameter	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2015	14/01/2015	04/02/2015	11/02/2015	Duplicate	26/03/2015	23/04/2015	21/05/2015	28/05/2015	02/06/2015
Total Suspended Solids	10	<3	<3	<3	9	<3	<3	<2	18	<3	3	5	4
Biochemical Oxygen Demand	1	<1	<1	<1	1.87 <sup>#</sup>	1.39 <sup>#</sup>	<1	<2	1.23 <sup>#</sup>	<1	1.29 <sup>#</sup>	<1	<1
pH	-	6.7	6.75	7	6.9	7.23 (6.73)	6.8 (7.33)	8.2	6.81 (7.05)	6.99	7.19	7.7	6.57
Total zinc	3	<18	<18	<18	20	<18	<18	5.394	<18	<18	<18	7.49	<18
Dissolved mercury	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.2	<0.1	<0.1	<0.1	<0.01	<0.1
Dissolved cadmium	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.09	<0.6	<0.6	<0.6	<0.1	<0.6
Dissolved iron	0.0047	2.07	0.52	0.67	0.39	0.36	0.36	0.6633	<0.23	1.34	1.34	1.47	0.52
Dissolved copper	3	<9	<9	<9	<9	<9	<9	7.207	<9	<9	<9	2.56	<9
Dissolved chromium	0.2	<2	<2	<2	<2	<2	<2	<0.68	<2	<2	<2	0.956	<2
Chromium VI	2	<5	<5	<5	<5	<5	<5		<5	<5	<5	<30	<5
Chromium III	2	<30	<30	<30	<30	<30	<30		<30	<30	<30	<30	<30
Dissolved nickel	0.2	<3	<3	<3	<3	<3	<3	0.702	<3	<3	<3	0.913	<3
Dissolved arsenic	0.9	2.4	<1	<1	<1	1.3	<1	1.197	2	3.2	2.2	3.69	1.2
Dissolved lead	0.4	<6	<6	<6	<6	<6	<6	0.284	<6	<6	<6	0.315	<6
Total hardness as CaCO <sub>3</sub>	1	21.7	16.2	21.1	30.1	24.2	19.7	19	13.4	33.1	17.6	29.4	9.98
Visible oil or grease	N/A	-	-	-	-	-	-	-	-	-	-	-	-

## Notes:

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are in µg/L.

<sup>#</sup> BOD over diluted, therefore result indicative only

<sup>Δ</sup> Container with headspace

## DCS3 - Curraghinalt Burn downstream

Parameter	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2014	14/01/2015	04/02/2015	11/02/2015	26/03/2015	23/04/2015	21/05/2015	28/05/2015	02/06/2015	Duplicate
Total Suspended Solids	10	3	8	4	5	3	5	28	72	<3	18	9	3
Biochemical Oxygen Demand	1	1.08 <sup>#</sup>	<1	<1	1.65 <sup>#</sup>	1.91 <sup>#</sup>	<1	1.31 <sup>#</sup>	<1	1.25 <sup>#</sup>	1.22 <sup>#</sup>	<1	<2
pH	-	7.19	7.46	6.95	7.44	7.16 (6.93)	7.45 (7.2)	6.91 (7.31)	7.82	7.88	7.76	6.81	7.4
Total zinc	3	<18	<18	<18	20	<18	<18	<18	<18	<18	11.2	<18	36.51
Dissolved mercury	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.01	<0.1	<0.2
Dissolved cadmium	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.1	<0.6	<0.09
Dissolved iron	0.0047	1.78	0.54	0.65	0.38	0.25	0.25	0.24	0.8	1.13	1.03	0.52	1.485
Dissolved copper	3	<9	<9	<9	<9	<9	<9	<9	<9	<9	5.58	<9	19.83
Dissolved chromium	0.2	<2	<2	<2	6	<2	<2	<2	<2	<2	1.8	<2	1.017
Chromium VI	2	<5	<5	<5	8	<5	<5	<5	<5	<5	<30	<5	
Chromium III	2	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	
Dissolved nickel	0.2	<3	<3	<3	<3	<3	4	<3	<3	<3	2.12	<3	6.816
Dissolved arsenic	0.9	2.1	<1	<1	<1	2	1.3	2.7	5.3	8.3	7.7	1.5	7.069
Dissolved lead	0.4	<6	<6	<6	<6	<6	<6	<6	<6	<6	0.187	<6	0.381
Total hardness as CaCO <sub>3</sub>	1	35.5	27.5	21	34.5	41.4	49.4	13.7	71.4	36.6	65.1	10.8	25
Visible oil or grease	N/A	-	-	-	-	-	-	-	-	-	-	-	-

## Notes:

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are in µg/L.

<sup>#</sup> BOD over diluted, therefore result indicative only

<sup>Δ</sup> Container with headspace

	28/07/2015	30/07/2015	04/08/2015	02/09/2015	01/10/2015	22/10/2015	05/11/2015
	9	<10	<10	32	<10	<10	17
	1.49 <sup>#Δ</sup>	1	2	1	2	<1	2
	5.94 (6.49)	6.85	5.74 (8.36)	7.46	6.75	7.34	7.74 (7.54)
	14	8	7	8	7	6	28
	0.51	<0.01	<0.01	<0.01	<0.5	<0.5	<0.5
	6.9	<0.03	<0.03	<0.03	<0.03	<0.03	0.09
	1.2	2.569	2.046	6.269	6.646	5.39	4.41
	9.6	<3	<3	4	<3	<3	4
	4.7	<0.2	0.6	1.2	0.4	<0.2	0.3
	<20	<2	<2	<2	<2	<2	<2
	<20	<2	<2	<2	<2	<2	<2
	3.1	0.7	1	1.6	1.3	0.3	0.7
	2.8	2.5	2.6	4.6	5.9	2.8	<0.9
	2.1	<0.4	<0.4	2.7	<0.4	<0.4	1.2
	<15	229	12	23	30	24	37
	-	-	-	-	-	-	-

	28/07/2015	30/07/2015	04/08/2015	02/09/2015	01/10/2015	22/10/2015	05/11/2015
	16	<10	<10	<10	<10	<10	10
	1.42 <sup>#Δ</sup>	1	2	1	1	<1	2
	6.02 (6.28)	7.12	5.95 (6.40)	7.12	6.45	7.46	7.73 (7.5)
	13	9	7	9	7	8	17
	<0.5	<0.01	<0.01	<0.01	0.6	<0.5	<0.5
	0.45	<0.03	<0.03	<0.03	<0.03	<0.03	0.07
	1.2	2.634	1.843	3.455	6.574	3.424	2.834
	4.2	3	<3	3	<3	<3	7
	4.6	<0.2	<0.2	<0.2	<0.2	<0.2	0.9
	<20	<2	<2	<2	<2	<2	<2
	<20	<2	<2	<2	<2	<2	<2
	4.6	0.7	0.4	2.4	1.4	2.3	2.5
	1.3	<0.9	2	3.4	6.5	3.9	3.6
	<1	1	0.7	1.2	0.9	<0.4	2.8
	<15	21	21	68	31	84	100
	-	-	-	-	-	-	-

## DCS4 - Owenkillew River upstream

Parameter	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2014	14/01/2015	04/02/2015	11/02/2015	26/03/2015	Duplicate	23/04/2015	Duplicate	21/05/2015
Total Suspended Solids	10	<3	<3	6	<3	<3	<3	42	43	<3	<2	6
Biochemical Oxygen Demand	1	<1	<1	<1	1.47 <sup>#</sup>	1.29 <sup>#</sup>	<1	2.57 <sup>#</sup>	8	<1	<2	1.95 <sup>#</sup>
pH	-	6.84	7.07	6.68	6.77	6.7 (5.92)	7.06 (8.15)	6.9 (8.54)	7.7	7.93	7.2	7.23
Total zinc	3	<18	<18	<18	<18	<18	<18	<18	9.716	<18	<0.63	<18
Dissolved mercury	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.2	<0.1	<0.03	<0.1
Dissolved cadmium	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.09	<0.6	<0.01	<0.6
Dissolved iron	0.0047	1.05	0.5	0.45	0.43	0.4	0.36	0.25	0.2771	0.56	0.806	0.53
Dissolved copper	3	<9	<9	<9	<9	<9	<9	<9	20.09	<9	0.445	<9
Dissolved chromium	0.2	<2	<2	<2	<2	<2	<2	<2	<0.68	<2	<0.58	<2
Chromium VI	2	<5	<5	<5	<5	<5	<5	<5		<5		<5
Chromium III	2	<30	<30	<30	<30	<30	<30	<30		<30		<30
Dissolved nickel	0.2	<3	57	<3	<3	<3	<3	4	6.45	<3	0.569	<3
Dissolved arsenic	0.9	<1	<1	<1	<1	<1	<1	4.8	5.032	1.5	1.399	1.4
Dissolved lead	0.4	<6	<6	<6	<6	<6	<6	<6	0.543	<6	<0.02	<6
Total hardness as CaCO <sub>3</sub>	1	28.8	24.3	19.1	25.1	31	27.9	17.6	21	37.5	38	23.7
Visible oil or grease	N/A	-	-	-	-	-	-	-	-	-	-	-

## Notes:

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are

<sup>#</sup> BOD over diluted, therefore result indicative only

<sup>Δ</sup> Container with headspace

## DCS5 - Owenkillew River downstream

Parameter	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2014	14/01/2015	04/02/2015	11/02/2015	23/03/2015	26/03/2015	23/04/2015	21/05/2015	Duplicate
Total Suspended Solids	10	<3	<3	8	<3	<3	<3	5	35	<3	<3	2
Biochemical Oxygen Demand	1	<1	<1	<1	1.61 <sup>#</sup>	1.37 <sup>#</sup>	<1	<2	2.59 <sup>#</sup>	<1	1.17 <sup>#</sup>	<2
pH	-	7.04	7.15	6.61	6.76	6.66 (5.54)	7.03 (7.45)	7.5	6.9 (6.77)	7.71	6.94	7.5
Total zinc	3	<18	<18	<18	<18	<18	<18	11.69	20	<18	<18	4.396
Dissolved mercury	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.2	<0.1	<0.1	<0.1	<0.2
Dissolved cadmium	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.09	<0.6	<0.6	<0.6	<0.09
Dissolved iron	0.0047	0.98	0.5	0.42	0.43	0.37	0.39	0.6379	0.25	0.58	0.56	0.5218
Dissolved copper	3	<9	<9	<9	<9	<9	<9	0.322	<9	<9	<9	2.819
Dissolved chromium	0.2	<2	<2	<2	<2	<2	<2	<0.68	<2	<2	<2	<0.68
Chromium VI	2	<5	<5	<5	8	<5	<5	<5	<5	<5	<5	
Chromium III	2	<30	<30	<30	<30	<30	<30	<30	<30	<30	<30	
Dissolved nickel	0.2	<3	<3	<3	<3	<3	<3	0.649	<3	<3	<3	0.997
Dissolved arsenic	0.9	<1	<1	<1	<1	1.2	<1	1.158	5	1.5	1.3	1.183
Dissolved lead	0.4	<6	<6	<6	<6	<6	<6	<0.173	<6	<6	<6	<0.173
Total hardness as CaCO <sub>3</sub>	1	29.3	23.8	18.2	25.3	31	27.1	35	17.2	41.6	23	25
Visible oil or grease	N/A	-	-	-	-	-	-	-	-	-	-	-

## Notes:

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are

<sup>#</sup> BOD over diluted, therefore result indicative only

<sup>Δ</sup> Container with headspace

02/06/2015	07/07/2015	28/07/2015	30/07/2015	04/08/2015	Duplicate	02/09/2015	01/10/2015	22/10/2015	05/11/2015
9	13	9	<10	12	3	<10	<10	<10	<10
1.28 <sup>#</sup>	2.47 <sup>#</sup>	1.95 <sup>#Δ</sup>	1	1	<2	2	1	2	2
6.79	(7.36)	6.1 (6.50)	6.68	7.28 (9.90)	7.4	7.79	6.45	7.46	7.65 (7.14)
<18	6.7	9.6	6	6	10.31	4	3	<3	3
<0.1	<0.5	<0.5	0.04	<0.01	<0.2	<0.01	0.6	<0.5	<0.5
<0.6	<0.08	0.6	<0.03	<0.03	<0.09	0.05	0.14	<0.03	0.08
0.36	0.56	0.78	1.146	2.459	1.482	1.806	1.503	0.9033	1.269
<9	1.1	3.2	<3	<3	11.24	<3	<3	<3	<3
<2	<1	5.8	<0.2	<0.2	<0.68	1	0.6	<0.2	<0.2
<5	<20	<20	<2	<2		<2	<2	<2	<2
<30	<20	<20	<2	<2		<2	<2	<2	<2
<3	<1	6.3	0.4	0.7	1.513	1.3	0.6	0.4	0.7
1.1	<1	1.2	2.4	2.4	3.454	2.2	2.8	1.6	<0.9
<6	<1	<1	2.2	0.5	0.573	4	<0.4	<0.4	1.9
16.2	30	<15	25	23	22	32	41	29	38
-	-	-	-	-	-	-	-	-	-

: in µg/L.

02/06/2015	07/07/2015	28/07/2015	30/07/2015	04/08/2015	02/09/2015	01/10/2015	22/10/2015	05/11/2015
<3	14	12	<10	<10	<10	<10	<10	<10
1.1 <sup>#</sup>	2.01 <sup>#</sup>	2.04 <sup>#Δ</sup>	1	2	1	1	<1	1
6.88	7.23 (7.41)	6.2 (6.96)	6.88	6.51 (7.41)	6.51	7.91	7.12	7.49 (7.11)
<18	8.8	11	7	5	5	<3	4	4
<0.1	<0.5	<0.5	0.05	0.03	0.01	<0.5	<0.5	<0.5
<0.6	<0.08	0.5	<0.03	<0.03	0.19	<0.03	0.2	0.14
0.38	0.63	0.83	1.241	2.749	1.835	1.938	1.312	1.37
<9	<1	3.2	<3	<3	<3	<3	<3	<3
<2	<1	6.5	<0.2	0.3	1	<0.2	<0.2	0.3
<5	<20	<20	<2	<2	<2	<2	<2	<2
<30	<20	<20	<2	<2	<2	<2	<2	<2
<3	<1	7.1	0.5	0.8	1.4	0.5	0.6	0.9
1.1	<1	1.2	2.4	5.4	<0.9	1.8	1.7	<0.9
<6	<1	<1	2.4	<0.4	2.2	<0.4	2.1	<0.4
16.3	31	<15	27	21	36	43	30	41
-	-	-	-	-	-	-	-	-

: in µg/L.

## DCS6 - Field Blanks

Parameter	Detection limit (typical)	27/11/2014	16/12/2014	18/12/2014	14/01/2015	04/02/2015	11/02/2015	11/02/2015	26/03/2015	23/04/2015	21/05/2015	02/06/2015	07/07/2015
Total Suspended Solids	10	<3	<3	<3	<3	<3	<3	<2	<3	<3	<3	<3	<3
Biochemical Oxygen Demand	1	<1	<1	<1	<1	<1	<1	<2	<1	<1	<1	<1	<1
pH	-	6.15	6.4	5.59	6	5.22	6.89	8.1	5.75	6.15	6.41	6.73	5.89
Total zinc	3	<18	<18	<18	<18	<18	<18	<3.73	<18	<18	<18	<18	4.7
Dissolved mercury	0.5	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.2	<0.1	<0.1	<0.1	<0.1	<0.5
Dissolved cadmium	0.03	<0.6	<0.6	<0.6	<0.6	<0.6	<0.6	<0.09	<0.6	<0.6	<0.6	<0.6	<0.08
Dissolved iron	0.0047	<0.23	<0.23	<0.23	<0.23	<0.23	<0.23	0.003	<0.23	<0.23	<0.23	<0.23	<0.02
Dissolved copper	3	<9	<9	<9	<9	<9	<9	1.454	<9	<9	<9	<9	<1
Dissolved chromium	0.2	<2	<2	<2	<2	<2	<2	<0.68	<2	<2	<2	<2	<1
Chromium VI	2	<5	<5	<5	11	<5	<5		<5	<5	<5	<5	<20
Chromium III	2	<30	<30	<30	<30	<30	<30		<30	<30	<30	<30	<20
Dissolved nickel	0.2	<3	<3	<3	<3	<3	<3	<0.374	<3	<3	<3	<3	<1
Dissolved arsenic	0.9	<1	<1	<1	<1	<1	<1	<0.352	<1	<1	<1	<1	<1
Dissolved lead	0.4	<6	<6	<6	<6	<6	<6	<0.173	<6	<6	<6	<6	<1
Total hardness as CaCO3	1	<3.2	<3.2	<3.2	<3.2	<3.2	<3.2	<5.2	<3.2	<3.2	<3.2	<3.2	<15
Visible oil or grease	N/A	-	-	-	-	-	-	-	-	-	-	-	-

**Notes:**

pH values presented in pH units. Values in brackets are field pH measurements. Total Suspended Solids, Biochemical Oxygen Demand, Total hardness & Dissolved iron concentrations are presented in mg/L, all other parameters are in µg/L

<sup>Δ</sup> Container with headspace

	28/07/2015	30/07/2015	04/08/2015	02/09/2015	01/10/2015	22/10/2015	05/11/2015
	<3	<10	<10	<10	<10	<10	<10
	<1 <sup>Δ</sup>	<1	<1	<1	<1	<1	<1
	5.91	5.67	5.76	5.37	7.68	7.77	7.29
	6.9	3	<3	<3	<3	<3	<3
	<0.5	<0.01	<0.01	<0.01	<0.5	<0.5	<0.5
	0.43	<0.03	<0.03	0.08	<0.03	0.04	<0.03
	<0.02	<0.0047	<0.0047	<0.0047	<0.0047	<0.0047	<0.0047
	1.9	<3	<3	<3	<3	<3	<3
	6.9	<0.2	<0.2	0.7	<0.2	<0.2	<0.2
	<20	<2	<2	<2	<2	<2	<2
	<20	<2	<2	<2	<2	<2	<2
	8.3	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2
	<1	<0.9	<0.9	<0.9	<0.9	<0.9	<0.9
	<1	1.6	<0.4	0.5	<0.4	1.1	<0.4
	<15	<1	<1	<1	<1	<1	<1
	-	-	-	-	-	-	-