

[REDACTED]

From: [REDACTED]@doeni.gov.uk>
Sent: 30 June 2015 09:26
To: [REDACTED]
Cc: [REDACTED]
Subject: Site Visit to Dalradian Gold Ltd Gortin 26 June 2015

[REDACTED]

WATER (NORTHERN IRELAND) ORDER 1999

Thank you for meeting with myself and my colleagues last Friday. I would like to outline below what we discussed at the meeting. You told us that the temporary Waste Water Effluent Treatment System has now been dismantled, and is no longer in use. You then took us to the new Waste Water Effluent Treatment System, which has been installed. You explained the process involved to us, which includes:

- Settlement,
- Hydrocarbon interceptor,
- Onsite Polyelectrolyte dosing
- Clarification
- pH adjustment
- Final discharge.

You told us that the system is maintained on a twenty four hour basis, and that a number of procedures have been built into the process to ensure that the effluent can be contained and controlled if any problems occur. You also told us that you have a service agreement with the company who installed the treatment system.

You explained to us that your company continues the sample monitoring of the entire site and surrounding waterways for base line and compliance information. You also explained to me that Stephen is preparing a report for the latest compliance self monitoring samples.

We agreed to meet up with you again within the next two months, to discuss any water quality issues, and site work progress.

Please contact me if you need any further information

Best Regards

[REDACTED]

Water Management Unit
Lisburn.

[REDACTED]
[REDACTED]