

[REDACTED]

---

**From:** [REDACTED]@dalradian.com>  
**Sent:** 08 March 2017 17:16  
**To:** [REDACTED]  
**Cc:** [REDACTED]  
**Subject:** RE: Water Quality Exceedance Advisory Email  
**Attachments:** Report 6Dec16.pdf; Report 18thJan17.pdf; Report 1stFeb17.pdf

Hi [REDACTED]

We have looked into the exceedance from our operations point of view and I cannot see any change in practice that would have caused the exceedance.

A sample was taken by Dalradian on the 18<sup>th</sup> of January (2 days before your department took the sample) and we can report a concentration of 25 ug/L at the discharge point. We also took a duplicate sample on the day too and we can report a concentration of 26 ug/L. Our quarterly report is due at the end of this month and I have attached the lab reports for Dalradian's sampling for this period. The maximum total Zinc concentration for this period is 29 ug/L which is below the limit of 33.8 ug/l.

Regards

[REDACTED]

---

**From:** [REDACTED]@daera-ni.gov.uk]  
**Sent:** 27 February 2017 09:34  
**To:** [REDACTED]  
**Cc:** [REDACTED]  
[REDACTED]  
[REDACTED]  
[REDACTED]  
**Subject:** Water Quality Exceedance Advisory Email

[REDACTED]

As discussed with you earlier today.

Consent Number 068/12/2  
File Reference TC 40/12\_2

A water quality sample was taken at your premises on 20 January 2017. The analytical result for Zinc was found to be in exceedance of the Departments consent limit.

Zinc consent limit = **33.8ug/l**  
Zinc water quality result= **45ug/l**

I would be grateful if you could please look into this matter.

Please contact me if you require any further assistance.

Best Regards  
[REDACTED]

Water Regulation Team  
Lisburn

[REDACTED]  
[REDACTED]